


Standard Power Cables

Low Voltage (600/1000 V)

BS5467



Cable Approvals

> Cable approved to BS5467



Conductor

> Plain annealed copper stranded (Class 2) conductor for ease of handling

Insulation

> 90°C cross-linked XLPE insulation complying with BS EN 60228 Class 2

Core Identification

- ○ blue-brown
 - ○ ○ brown-black-grey
 - ○ ○ ○ blue-brown-black-grey
 - ○ ○ ○ ○ blue-brown-black-grey-green/yellow
- 7 - 48 cores white with printed numbers

Bedding

> Extruded bedding compound

Outer Sheath

> PVC Sheath

Armour

- > Single layer of galvanized steel wires
- > Aluminium wires on single core



Temperature Range
-15 to +90°C



Bending Radius
Circular conductor $r = 6D$
Shaped conductor $r = 8D$



Mechanical Impact
Very Good



Fire Performance
BS EN 60332-1-2



Flexibility
Rigid

BS5467

Cable Details

Standard current ratings from ERA 69-30pt V

Ambient temperature (air)	25°C
Ground Temperature	15°C
Depth of burial	0.5m
Thermal resistance of soil	1.2°C m/w
Armour bonded and earthed at both ends	Yes

NOTE: If current rating in buildings is required reference should be made to BS7671 (IEE Wiring Regs). Alternatively rating are as BS6724 cables

Nominal cross sectional area	Approx. overall dia.	Approx. Dia. Under Armour	Nominal dia. of armour wires	Approx. cable weight	Max. conductor resistance @ 20°C	Conductor short circuit rating (1 sec)	Current rating				Volt drop single phase AC touching	Volt drop Three phase AC trefoil
							Single phase AC in air horizontal spaced	Three phase in ground trefoil formation	Three phase in Trefoil Duct	Three phase in air trefoil formation		
mm ²	mm	mm	mm	kg/km	Ohms/km	kA	Amps	Amps	Amps		mV/A/m	mV/A/m

Single Core

150	25.8	19.5	1.6	1950	0.1240	21.4	510	431	396	483	0.38	0.33
185	28.0	21.6	1.6	2350	0.0991	26.4	574	485	437	555	0.33	0.28
240	30.5	23.9	1.6	3000	0.0754	34.3	661	558	489	654	0.28	0.24
300	33.5	26.5	1.6	3675	0.0601	42.9	739	623	534	745	0.25	0.21
400	37.8	30.4	2.0	4700	0.0470	57.2	820	691	567	851	0.22	0.195
500	41.1	33.9	2.0	5925	0.0366	71.5	910	765	615	963	0.21	0.18
630	45.3	38.2	2.0	7450	0.0283	90.1	1001	841	664	1084	0.195	0.17
800	54.8	43.7	2.5	9400	0.0221	114	1055	888	692	1178	0.19	0.165
1000	58.4	48.5	2.5	11400	0.0176	143	1115	942	735	1278	0.18	0.155

Single phase AC Volt drop- If the cable spacing is larger than 1 cable diameter then the volt drop will be larger than those specified.

If current rating in buildings is required reference should be made to BS7671 (IET Wiring Regs). Alternatively rating are as BS6724 cables.

Cable Details

Nominal cross sectional area	Approx. overall diameter	Approx. diameter under armour	Nominal diameter of armour wires	Approx. cable weight	Maximum conductor resistance @ 20°C	Conductor short circuit rating (1 sec)	Armour short circuit rating (1sec)	Current rating			Volt drop single phase AC touching
								Direct in ground	In duct	In air	
mm ²	mm	mm	mm	kg/km	Ohms/km		kA	Amps	Amps	Amps	mV/A/m
Two Core											
1.5	11.5	7.1	0.9	320	12.1	0.20	0.65	38	31	31	31
2.5	12.9	8.3	0.9	365	7.41	0.35	0.75	49	41	41	19
4	14.4	9.8	0.9	440	4.61	0.57	0.85	65	53	55	12
6	15.6	11	0.9	470	3.08	0.86	1.0	81	67	70	7.9
10	16.8	12	0.9	810	1.83	1.4	1.2	109	89	95	4.7
16	19.6	14.1	1.25	1025	1.15	2.2	1.9	141	115	126	2.9
25*	20.9	15.6	1.25	1000	0.727	3.6	1.9	183	148	164	1.9
35*	23	17	1.6	1400	0.524	5.0	2.8	219	178	202	1.35
50*	25.3	19.3	1.6	1750	0.387	7.1	3.1	259	211	244	1
70*	28.5	22.3	1.6	2300	0.268	10.0	3.7	317	260	306	0.69
95*	32.3	25.1	2	3100	0.193	13.6	5.2	381	313	378	0.52
120*	34.8	27.4	2	3700	0.153	17.2	5.8	433	357	437	0.42
150*	37.9	30.3	2	4400	0.124	21.4	6.4	485	401	499	0.35
185*	42.5	33.5	2.5	5700	0.0991	26.5	8.8	547	455	576	0.29
240*	46.5	37.3	2.5	7100	0.0754	34.3	9.9	632	527	680	0.24
300*	50.3	40.9	2.5	8500	0.0601	42.9	10.9	708	592	775	0.21
400*	54.7	45.1	2.5	10700	0.047	57.2	12.2	799	669	892	0.19
Seven Core											
1.5	15.8	10.7	0.9	500	12.1	0.20	1.0	38	31	31	31
2.5	17.6	12.5	0.9	730	7.41	0.35	1.1	49	41	41	19
4	20.1	14.1	1.25	840	4.61	0.57	1.8	65	53	55	12
Twelve Core											
1.5	20	14	1.25	820	12.1	0.20	1.8	38	31	31	31
2.5	22.8	16.6	1.25	1020	7.41	0.35	0.2	49	41	41	19
4	26.1	19.2	1.6	1390	4.61	0.57	3.1	65	53	-	12
Nineteen Core											
1.5	22.6	16.4	1.25	1080	12.1	0.20	2.1	38	31	31	31
2.5	27	19.9	1.6	1530	7.41	0.35	3.2	49	41	41	19
4	29.7	22.6	1.6	1850	4.61	0.57	3.7	65	53	55	12
Twenty-Seven Core											
1.5	27.3	20.0	1.6	1850	12.1	0.20	3.8	38	31	31	31
2.5	31.3	24	1.6	1960	7.41	0.35	3.8	49	41	41	19
4	34.8	27.3	1.6	2420	4.61	0.57	4.4	65	53	55	12
Thirty Seven Core											
1.5	29.9	22.5	1.6	1850	12.1	0.20	3.8	38	31	31	31
2.5	34.3	27	1.6	2440	7.41	0.35	4.3	49	41	41	19
4	39.6	31.1	2	3320	4.61	0.57	6.4	65	53	55	12
Forty Eight Core											
1.5	33.5	26	1.6	2900	12.1	0.20	4.1	38	31	31	31
2.5	40.1	31.4	2	3550	7.41	0.35	6.4	49	41	41	19
4	44.7	35.8	2	4850	4.61	0.57	7.2	65	53	55	-

* Shaped conductors, all others are Circular conductors

For auxiliary cables having greater than 4 loaded cores apply derating as given in table 4B5 of IET wiring regulations.

Cable Details

Nominal cross sectional area	Approx. overall diameter	Approx. diameter under armour	Nominal diameter of armour wires	Approx. cable weight	Maximum conductor resistance @ 20°C	Conductor short circuit rating (1 sec)	Armour short circuit rating (1sec)	Current rating			Volt drop Three phase AC
								Direct in ground	In duct	In air	
mm ²	mm	mm	mm	kg/km	Ohms/km	kA	kA	Amps	Amps	Amps	mV/A/m
Three Core											
1.5	12	8	0.9	300	12.1	0.20	0.74	32	26	26	27
2.5	13	9	0.9	350	7.41	0.35	0.88	42	34	35	16
4	15	10	0.9	450	4.61	0.57	0.97	55	45	47	10
6	16	11	0.9	550	3.08	0.86	1.0	69	56	59	6.8
10	18	13	1.25	800	1.83	1.4	1.8	92	75	82	4
16	21	15	1.25	1100	1.15	2.2	2.0	119	96	107	2.5
25	26	19	1.6	1700	0.727	3.6	2.8	152	124	140	1.65
35	28	22	1.6	2100	0.524	5.0	3.0	182	149	172	1.15
50*	30	23	1.6	2400	0.387	7.1	3.6	217	177	209	0.87
70*	34	26	1.6	3100	0.268	10.0	4.1	266	218	263	0.6
95*	36	29	2	4100	0.193	13.6	5.9	319	263	324	0.45
120*	40	32	2	5000	0.153	17.2	6.5	363	300	376	0.37
150*	45	36	2.5	6300	0.124	21.4	9.3	406	338	430	0.3
185*	49	40	2.5	7600	0.0991	26.5	10.2	458	382	495	0.26
240*	54	44	2.5	9600	0.0754	34.3	11.6	529	442	584	0.21
300*	59	49	2.5	11600	0.0601	42.9	12.4	592	496	666	0.185
400*	65	55	2.5	14400	0.047	57.2	14.1	667	570	766	0.165
Four Core											
1.5	12.9	8.3	0.9	400	12.1	0.20	0.78	32	26	26	27
2.5	14.4	9.8	0.9	470	7.41	0.35	0.92	42	34	35	16
4	15.7	11.1	0.9	580	4.61	0.57	1.0	55	45	47	10
6	17.9	12.4	1.25	810	3.08	0.86	1.6	69	56	59	6.8
10	19.7	14.2	1.25	10875	1.83	1.4	1.9	92	75	82	4
16	22.4	16.7	1.25	1450	1.15	2.2	2.2	119	96	107	2.5
25	27.3	20.7	1.6	2060	0.727	3.6	3.2	152	124	140	1.65
35	30.2	23.4	1.6	2550	0.524	5.0	3.7	182	149	172	1.15
50*	32.2	26	1.6	2875	0.387	7.1	4.1	217	177	209	0.87
70*	38	30.6	2	4250	0.268	10.0	6.1	266	218	263	0.6
95*	41.7	34.1	2	5475	0.193	13.6	6.8	319	263	324	0.45
120*	45.4	37.6	2.5	7175	0.153	17.2	9.5	363	300	376	0.37
150*	50.6	41.6	2.5	8475	0.124	21.4	10.6	406	338	430	0.3
185*	55.3	46	2.5	10350	0.0991	26.5	11.8	458	382	495	0.26
240*	61.2	51.7	2.5	13000	0.0754	34.3	13.4	529	442	584	0.21
300*	66.8	56.9	2.5	15750	0.0601	42.9	14.8	592	496	666	0.185
400*	75.4	64	3.15	20400	0.047	57.2	20.9	667	570	766	0.165
Five Core											
1.5	14.9	9.8	0.9	400	12.1	0.20	0.88	32	26	26	27
2.5	16.5	11.4	0.9	490	7.41	0.35	1.0	42	34	35	16
4	18.9	12.9	1.25	715	4.61	0.57	1.1	55	45	47	10
6	20.4	14.4	1.25	900	3.08	0.86	1.8	69	56	59	6.8
10	23.2	17	1.25	1200	1.83	1.4	2.1	92	75	82	4
16	27.3	20.2	1.6	1650	1.15	2.2	3.3	119	96	107	2.5
25	30	24	1.6	2200	0.727	3.6	4.0	152	124	140	1.65
35	32.9	26.7	1.6	2700	0.524	5.0	4.6	182	149	172	1.15

* Shaped conductors, all others are Circular conductors

Resistance & Area of Armour

Nominal cross sectional area	Conductor Resistance at 20°C	Nominal Area of Armour and Maximum Armour Resistance at 20°C									
		Single Core*		Two Core		Three Core		Four Core		Five Core	
		mm ²	Ohms/km	mm ²	Ohms/km	mm ²	Ohms/km	mm ²	Ohms/km	mm ²	Ohms/km
1.5	12.1	-	-	15	10.2	16	9.5	17	8.8	19	8.2
2.5	7.41	-	-	17	8.8	19	8.2	20	7.7	22	6.8
4	4.61	-	-	19	7.9	20	7.5	22	6.8	25	6.2
6	3.08	-	-	22	7.0	23	6.7	36	4.3	40	3.9
10	1.83	-	-	26	6.0	39	4.0	42	3.7	46	3.4
16	1.15	-	-	42	3.7	45	3.5	50	3.1	72	2.2
25	0.727	-	-	42	3.7	62	2.5	70	2.3	88	1.8
35	0.524	-	-	60	2.6	68	2.3	78	2.0	100	1.6
50	0.387	-	-	68	2.3	78	2.0	90	1.8	-	-
70	0.268	-	-	80	2.0	90	1.8	131	1.2	-	-
95	0.193	-	-	113	1.4	128	1.3	147	1.1	-	-
120	0.153	-	-	125	1.3	141	1.2	206	0.76	-	-
150	0.124	76	0.42	138	1.2	201	0.78	230	0.68	-	-
185	0.0991	84	0.38	191	0.82	220	0.71	255	0.61	-	-
240	0.0754	94	0.34	215	0.73	250	0.63	289	0.54	-	-
300	0.0601	104	0.31	235	0.67	269	0.58	319	0.49	-	-
400	0.0470	147	0.22	265	0.59	304	0.52	452	0.35	-	-
500	0.0366	163	0.20	-	-	-	-	-	-	-	-
630	0.0283	182	0.18	-	-	-	-	-	-	-	-
800	0.0221	260	0.13	-	-	-	-	-	-	-	-
1000	0.0176	284	0.12	-	-	-	-	-	-	-	-

* Armour wires for single core cables are aluminium.

No. of Cores	Nominal Area of Armour and Maximum Armour Resistance at 20 °C					
	1.5mm ²		2.5mm ²		4.0mm ²	
	mm ²	Ohms/km	mm ²	Ohms/km	mm ²	Ohms/km
7	20	7.5	24	6.3	39	4.0
12	39	4.0	45	3.5	68	2.3
19	45	3.5	70	2.3	80	2.0
27	70	2.3	84	1.9	96	1.7
37	78	2.0	94	1.7	138	1.2
48	90	1.8	138	1.2	157	1.0

Certificate of Product Approval

Licensee:

Prysmian Cables & Systems Ltd

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:
Harriet Street

Trecynon, Aberdare, CF44 0TD, Glamorgan, United Kingdom

Standard:
BS 5467:2016 Incorporating Corrigendum No. 1

Description:
Thermosetting insulated, armoured cables with rated voltages of
600/1000v PVC sheathing

Details:
N/A

Materials:
Insulation GP 8, Sheath Type 9

Brand Name:
N/A

Origin Mark:
BRITCABLE (A) or PRYSMIAN (A)

Permissible Approval Marks:

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of
BASEC Group Ltd

Kieran O'Brien Date: 06/07/2023

Date of original issue: 26/05/1994

Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
11/08/2026



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
5	6942X	Class 2	2	1.5	35
6	6943X	Class 2	3	1.5	35
7	6944X	Class 2	4	1.5	35
8	6945X	Class 2	5	1.5	35

Signed for and on behalf of
BASEC Group Ltd

Kieran O'Brien Date: 06/07/2023

Date of original issue: 26/05/1994

Check BASEC website to verify validity.

Page 2 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No.13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
11/08/2026

Certificate of Product Approval

Licensee:

Prysmian Cables & Systems Ltd

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Standard:

BS 5467:2016 Incorporating Corrigendum No. 1

Description:

Thermosetting insulated, armoured cables with rated voltages of 600/1000v with PVC sheathing

Details:

N/A

Materials:

Insulation GP 8, Sheath Type 9

Brand Name:

N/A

Origin Mark:

BRITCABLE (B) or (B) BRITCABLE or PRYSMIAN (B) or (B) PRYSMIAN

Permissible Approval Marks:

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of
BASEC Group Ltd

Kieran O'Brien Date: 06/07/2023

Date of original issue: 27/07/1994

Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
11/08/2026



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size -sqmm
5	6942X	Class 2	2	1.5	70
6	6943X	Class 2	3	1.5	70
7	6944X	Class 2	4	1.5	70
8	6945X	Class 2	5	1.5	10
9	6947X	Class 2	7	1.5	4
9	6940/12X	Class 2	12	1.5	4
9	6940/19X	Class 2	19	1.5	4
9	6940/27X	Class 2	27	1.5	4
9	6940/37X	Class 2	37	1.5	4

Signed for and on behalf of
BASEC Group Ltd

Kieran O'Brien Date: 06/07/2023

Date of original issue: 27/07/1994

Check BASEC website to verify validity.

Page 2 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No.13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
11/08/2026

Certificate of Product Approval

Licensee:

Prysmian Cables & Systems Ltd

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:
Oak Road

Wrexham Industrial Estate, Wrexham, LL13 9PH, Clwyd, United Kingdom

Standard:
BS 5467:2016 Incorporating Corrigendum No. 1

Description:
Armoured power cables with PVC sheathing

Details:
600/1000V

Materials:
Insulation GP 8, Sheath Type 9

Brand Name:
N/A

Origin Mark:
PRYSMIAN (W) or BRITCABLE (W)

Permissible Approval Marks:

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of
BASEC Group Ltd

Kieran O'Brien Date: 20/07/2023

Date of original issue: 13/02/2001

Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
11/08/2026



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
4	6941X	Class 2	1	120	1000
5	6942X	Class 2	2	70	400
6	6943X	Class 2	3	70	400
7	6944X	Class 2	4	70	400

Signed for and on behalf of
BASEC Group Ltd

Kieran O'Brien Date: 20/07/2023

Date of original issue: 13/02/2001

Check BASEC website to verify validity.

Page 2 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No.13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
11/08/2026