



**FIRE RESISTANT CABLES**



**FP400®**

# FIRE RESISTANT CABLES

## FP400® BS7846-F2

FP400®



APPROVALS

INSTALLATION



Certificate No 077b  
Certificate No 517b



- > Pysmian FP400® is the original fire resistant armoured cable providing an easy to install and terminate, robust fire resistant wiring system. In addition to maintaining circuit integrity during a fire, FP400® produces very low levels of smoke and virtually no (less than 0.5%) acidic gases, thus safeguarding human life and protecting equipment.

FP400® handles like a standard armoured cable and can be installed just as easily. No special tools or accessories are needed for installation or termination of FP400®, which ensures that substantial installation cost savings, compared with MICC, can be achieved through its use.

FP400® is suitable for indoor or outdoor installation requiring a robust armoured cable, including direct burial, trough, fixed direct, tray or ladder.

Pysmian FP400® complies with BS7846 Category F2 which ensures that it complies with the requirements for "protected power circuits" given in the 2000 edition of Approved Document B Fire safety of The Building Regulations 2000.

- > Pysmian FP400® is British Approvals Service for Cables (BSEC) approved to BS7846 Category F2. It is also Loss Prevention Certification Board (LPCB) listed as a fire resistant cable and approved to BS6387 Category CWZ, at an enhanced voltage of 600/1000V.

Witnessed ad-hoc tests have demonstrated the ability of FP400® to achieve fire resistant properties in excess of those required by BS6387 Category CWZ and on the basis of these tests Pysmian FP400® has been approved for many projects where previously only MICC had been approved.

Additional tests have demonstrated the ability of FP400® to achieve a 60 minute rating (PH60) to BS EN50200 and a 30 minute rating to BS8434-1. These tests demonstrate that FP400® also meets the requirements for use in "standard" installations in accordance with BS5839-1:2002 for fire detection and alarm systems, and "Cables with inherently high resistance to attack by fire" in accordance with BS5266-1:2005 for emergency lighting.

All Pysmian FP400® cables are manufactured under an ISO 9001 Quality System certified by BSEC and LPCB.

- > Pysmian FP400® may be considered as a low smoke armoured cable to BS6724 for the purposes of installation and should be installed in accordance with BS7671/IEE Wiring Regulations or any other appropriate national regulations. Although standard armour cable fixings and glands may be used, it is important to ensure that, when the cable is required to maintain circuit integrity in a fire, any fixing used to support the cable can also withstand that fire. The use of the appropriate BICON® gland or cleat is recommended.

### CABLE CHARACTERISTICS



Temperature Range  
-25 to +90°C



Bending Radius  
Circular conductor r=6D  
Shaped conductor r=8D



Mechanical Impact  
Very Good



Fire Performance  
BSEN60332-1-2  
BSEN50266-2-4



Flexibility  
Rigid



Halogen Free  
BSEN50267-2-1



Low Smoke Emissions  
BSEN61034-2



Fire Resistant  
BS6387  
Category  
CWZ

Nominal cross sectional area mm <sup>2</sup>	Approximate overall diameter mm	Approximate diameter under armour mm	Nominal diameter of armour wires mm	Approximate cable weight kg/km	Maximum conductor resistance at 20°C ohms/km	Short Circuit rating (1 sec) of conductor KA	Current rating Three phase AC Clipped direct Amps	Current rating Three phase AC Free Air Amps	Volt drop Three phase AC mV/A/m
--	---------------------------------	--------------------------------------	-------------------------------------	--------------------------------	--	--	---	---	---------------------------------

**Three Core**

1.5	13.4	8.8	0.9	340	12.1	0.20	23	25	27
2.5	14.8	10.2	0.9	430	7.41	0.35	31	33	16
4	16.1	11.5	0.9	510	4.61	0.57	42	44	10
6	17.4	12.8	0.9	620	3.08	0.86	53	56	6.8
10	20.3	14.8	1.25	930	1.83	1.4	73	78	4.0
16	22.8	17.1	1.25	1210	1.15	2.2	94	99	2.5
25	27.4	20.8	1.6	1800	0.727	3.6	124	131	1.65
35	29.2	22.4	1.6	2100	0.524	5.0	154	162	1.15
50	33.0	26.2	1.6	2600	0.387	7.1	187	197	0.87
70	37.0	30.0	1.6	3400	0.268	10.0	238	251	0.60
95	40.6	32.4	2.0	4500	0.193	13.6	389	304	0.45
120	43.8	35.4	2.0	5500	0.153	17.2	335	353	0.37
150	48.0	38.4	2.5	6900	0.124	21.4	386	406	0.30
185	52.0	42.2	2.5	8200	0.0991	26.5	441	463	0.26
240	57.1	46.9	2.5	10200	0.0754	34.3	520	546	0.21
300	63.0	52.6	2.5	12200	0.0601	42.9	599	628	0.185
400	69.5	58.7	2.5	15000	0.0470	57.2	673	728	0.165

**Four Core**

1.5	14.3	9.7	0.9	390	12.1	0.20	23	25	27
2.5	16.0	11.4	0.9	490	7.41	0.35	31	33	16
4	17.3	12.7	0.9	590	4.61	0.57	42	44	10
6	19.6	14.1	1.25	830	3.08	0.86	53	56	6.8
10	21.8	16.3	1.25	1040	1.83	1.4	73	78	4.0
16	24.6	18.9	1.25	1370	1.15	2.2	94	99	2.5
25	29.1	22.5	1.6	2100	0.727	3.6	124	131	1.65
35	32.2	25.4	1.6	2500	0.524	5.0	154	162	1.15
50	35.0	28.0	1.6	3200	0.387	7.1	187	197	0.87
70	40.2	32.0	2.0	4500	0.268	10.0	238	251	0.60
95	44.0	35.6	2.0	5600	0.193	13.6	289	304	0.45
120	48.4	38.8	2.5	7200	0.153	17.2	335	353	0.37
150	52.5	42.7	2.5	8500	0.124	21.4	386	406	0.30
185	57.1	46.9	2.5	10300	0.0991	26.5	441	463	0.26
240	62.7	52.3	2.5	12800	0.0754	34.3	520	546	0.21
300	69.6	58.8	2.5	15600	0.0601	42.9	599	628	0.185
400	78.0	65.3	3.15	20400	0.0470	57.2	673	728	0.165

Circular conductor 1.5 - 35mm<sup>2</sup>.

Shaped conductor 50mm<sup>2</sup> and above.

Installation methods for current rating in accordance with BS7671/IEE Wiring Regulations.

The tabulated ratings are based upon a 30°C ambient temperature and 90°C operating temperature.

# LOW VOLTAGE 600/1000V

Nominal cross sectional area mm <sup>2</sup>	Approximate overall diameter mm	Approximate diameter under armour mm	Nominal diameter of armour wires mm	Approximate cable weight kg/km	Maximum conductor resistance at 20°C ohms/km	Current rating DC or Single phase AC Clipped direct Amps	Current rating DC or Single phase AC Free Air Amps	Volt drop DC mV/A/m	Volt drop Single phase AC mV/A/m
<b>Two Core</b>									
1.5	12.9	8.3	0.9	310	12.1	27	29	31	31
2.5	14.1	9.6	0.9	380	7.41	36	39	19	19
4	15.2	10.6	0.9	450	4.61	49	52	12	12
6	16.4	12.0	0.9	530	3.08	62	66	7.9	7.9
10	18.6	14.0	0.9	630	1.83	85	90	4.7	4.7
16	21.4	15.9	0.9	920	1.15	110	115	2.9	2.9
25	23.7	18.3	1.25	1200	0.727	146	152	1.85	1.9
35	27.2	20.9	1.6	1600	0.524	180	188	1.35	1.35
50	28.0	21.2	1.6	2000	0.387	219	228	0.98	1.00
70	30.7	23.7	1.6	2400	0.268	279	291	0.67	0.69
95	35.3	27.3	2.0	3300	0.193	338	354	0.49	0.52
120	36.6	28.4	2.0	3800	0.153	392	410	0.39	0.42
150	39.3	30.9	2.0	4400	0.124	451	472	0.31	0.35
185	44.2	34.4	2.5	5700	0.0991	515	539	0.25	0.29
240	48.0	38.0	2.5	7200	0.0754	637	636	0.195	0.24
300	51.8	41.6	2.5	8300	0.0601	698	732	0.155	0.21
400	55.9	45.3	2.5	10500	0.0470	787	847	0.120	0.19
<b>Seven Core</b>									
1.5	16.4	11.8	0.9	500	12.1	27 *	29 *	31	31
2.5	18.3	13.7	0.9	640	7.41	36 *	39 *	19	19
4	20.8	15.3	1.25	910	4.61	49 *	52 *	12	12
<b>Twelve Core</b>									
1.5	21.2	15.7	1.25	850	12.1	27 *	29 *	31	31
2.5	24.0	18.3	1.25	1090	7.41	36 *	39 *	19	19
4	27.3	20.9	1.6	1550	4.61	49 *	52 *	12	12
<b>Nineteen Core</b>									
1.5	24.2	18.5	1.25	1120	12.1	27 *	29 *	31	31
2.5	28.6	22.0	1.6	1650	7.41	36 *	39 *	19	19
<b>Twenty-seven Core</b>									
1.5	29.4	22.8	1.6	1650	12.1	27 *	29 *	31	31
2.5	33.4	26.6	1.6	2150	7.41	36 *	39 *	19	19
<b>Thirty-seven Core</b>									
1.5	32.2	25.6	1.6	2000	12.1	27 *	29 *	31	31
2.5	36.7	29.9	1.6	2650	7.41	36 *	39 *	19	19

\*The tabulated rating is as a two core cable and may be used where the number of cores carrying current does not exceed its square root of the total number of cores.

## KEY APPLICATIONS

- > Essential safety circuits associated with fire detection, fire alarm, emergency lighting and particularly for power supplies to building equipment used in safety systems.

## CABLE DESCRIPTION:

### CONDUCTOR

Plain annealed copper stranded (class 2) conductor for ease of handling.

### PRIMARY INSULATION

Mineral ceramic (Mica/Glass) fire resistant tape

### SECONDARY INSULATION

90°C cross - linked insulation

## CORE IDENTIFICATION:

### HARMONISED CORE IDENTIFICATION:

- ○ brown-blue
- ○ ○ brown-black-grey
- ○ ○ blue-brown-black-grey
- 7-48 cores white with printed numbers

### NON HARMONISED CORE IDENTIFICATION:

- ○ red-black
- ○ ○ red-yellow-blue
- ○ ○ black-red-yellow-blue
- Non harmonised colours to special order.

### BEDDING

Extruded LSOH bedding compound.

### ARMOUR

Single layer of galvanised steel wires.

### SHEATH

Robust LSOH sheath. Colour - black.  
Other colours to special order

## INSTALLATION

Minimum recommended installation temperature 0°C.

Suitable for indoor and outdoor installations. For external exposure the use of a Black sheath is recommended.

Should be installed in accordance with BS7671/IEE Wiring Regulations or any other appropriate national regulations.

Suitable for direct burial, trough, tray, ladder or other installations requiring a robust armoured cable.

## BENDING RADIUS

A minimum internal radius of bend of 6 x cable diameter is recommended during installations for cables having circular conductors and 8 x cable diameter for cables having shaped conductors.

## ACCESSORIES

No special accessories are required for the installation of FP400®.

Standard brass armoured cable glands may be used.

When the cable is required to maintain circuit integrity in a fire, it is important that any accessory used to support the cable can also withstand that fire.

## CURRENT RATINGS

The tabulated ratings are based upon a 30°C ambient temperature and a 90°C operating temperature. For other ambient temperatures or where cables are grouped together, the following correction factors should be applied.

### Correction factors for Ambient temperatures

Ambient Temperature °C	25	30	35	40	45	50	55	60
Correction factor	1.02	1.00	0.96	0.91	0.87	0.82	0.76	0.71

### Correction factors for grouping of cables

Installation Method		Number of circuits or multi-core cables							
		2	3	4	5	6	7	8	9
Single layer clipped to a non-metallic surface	Touching	0.85	0.79	0.75	0.73	0.72	0.72	0.71	0.70
	Spaced*	0.94	0.90	0.90	0.90	0.90	0.90	0.90	0.90
Single layer multicore on a perforated metal cable tray, vertical or horizontal	Touching	0.86	0.81	0.77	0.75	0.74	0.73	0.73	0.72
	Spaced*	0.91	0.89	0.88	0.87	0.87	-	-	-

\* Spaced by a clearance between adjacent surfaces of at least one cable diameter.

Where the horizontal clearance between adjacent cables exceeds 2 cable diameters no correction factor need be applied

Note. Standard conditions of grouping as stated in BS7671 IEE Wiring Regs apply

UK Sales enquiries  
Tel: 0845 767 8345  
Fax: 023 8029 5465

Overseas Sales enquiries  
Tel: +44 23 8029 5481  
Fax: +44 23 8089 5465

Information hotline  
Tel: +44 (0) 23 8029 5029  
Fax: +44 (0) 23 8029 5437  
[cables.marketing.uk@prysmian.com](mailto:cables.marketing.uk@prysmian.com)

[www.prysmian.co.uk](http://www.prysmian.co.uk)

UK Technical helpline  
Tel: 0845 767 8345  
Fax: 023 8029 5002

Overseas Technical helpline  
Tel: +44 23 8029 5481  
Fax: +44 23 8029 5002

Prysmian Cables & Systems Limited  
Chickenhall Lane  
Eastleigh  
Hampshire  
SO50 6YU  
United Kingdom

member of  
**voltimum**  
.co.uk

## Certificate of Management System Registration

Certificate Number: 77

Issue: 18

### Prysmian Cables & Systems Limited

having complied with the requirements of:

#### ISO 9001:2015

Quality Management Systems - Requirements

are certified by BRE Global Ltd. and are authorised to use the LPCB Certification Mark on stationery and publications related to the following products and/or services:

#### Prysmian Cables & Systems Limited

Energy Cables Division  
Chickenhall Lane  
Eastleigh  
Hampshire  
SO50 6YU  
United Kingdom

#### Scope:

Design and manufacture of electric cables for use in installations that require safety in the event of fire.

This certificate is maintained and held in force through regular surveillance activities.



Ruben Graham

1 December 2022

30 November 2025

13 February 1992

Signed for BRE Global

Assessment Services

Date of this Issue

Expiry Date

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Certificate of Product Approval

Certificate Number: 077b

Issue: 13

### PRYSMIAN CABLE & SYSTEMS LIMITED

Energy Cables  
Chickenhall Lane  
Bishopstoke  
Eastleigh  
Hants  
SO50 6YU  
United Kingdom

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Product(s)

Cable Types as listed below:  
FP300 fire resistant cable LSOH outer covering  
FP400 fire resistant cable LSOH outer covering

#### Standard(s) (see Appendix for details)

BS 6387:2013 CWZ  
EN 61034-2:2005+A1:2013  
EN 60754-1:2014

See Certificate Appendix for details

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Damien Ward*

Signed for LPCB

Damien Ward  
Certification Scheme Manager

28 October 2016  
Date of Issue

30 November 1994  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)





## Appendix to Certificate No: 077b PRYSMIAN CABLE & SYSTEMS LIMITED

Issue: 13

Product name				LPCB Ref. No.
FP300 fire resistant cable LSOH outer covering				077b/01
Nominal csa of conductor (mm <sup>2</sup> )	Core Construction (excluding drain wire and earth)	BS 6387	EN 61034-2	EN 60754-1 (outer covering)
1.0	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
1.5	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
2.5	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
4.0	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
6.0	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
10	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
16	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI

U<sub>o</sub>/U 600/1000V

**Notes:**

1. Stranded conductor only.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Damien Ward*

Signed for LPCB

Damien Ward  
Certification Scheme Manager

28 October 2016  
Date of Issue

30 November 1994  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



## Appendix to Certificate No: 077b PRYSMIAN CABLE & SYSTEMS LIMITED

Issue: 13

Product name				LPCB Ref. No.
FP400 fire resistant cable LSOH outer covering				077b/02
Nominal csa of conductor (mm <sup>2</sup> )	Core Construction	BS 6387	EN 61034-2	EN 60754-1 (outer covering)
1.5	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
2.5	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
4.0	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
6.0	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
10	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
16	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
25	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
35	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
50	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
70	2, & 3 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI

### U<sub>0</sub>/U 600/1000 V

#### Notes:

1. Stranded conductors only.
2. Testing of the FP400 range with diameters greater than 20mm were successfully carried out in accordance with Clause 17.6.2 and Annex I of BS 7846:2015.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Damien Ward*

Signed for LPCB

Damien Ward  
Certification Scheme Manager

28 October 2016  
Date of Issue

30 November 1994  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



**bre**

## Certificate of Product Approval

Certificate Number: 517b

Issue: 06

### PRYSMIAN CABLE & SYSTEMS LIMITED

Energy Cables Unit  
Wrexham Industrial Estate  
Wrexham  
LL13 9PH  
United Kingdom



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Product(s)

Cable Types as listed below:  
FP400 Fire Resistant Cable  
See Certificate Appendix for details

#### Standard(s) (see Appendix for details)

BS 6387:2013 CWZ  
EN 61034-2:2005+A1:2013  
EN 60754-1:2014

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Damien Ward*

Signed for LPCB

Damien Ward  
Certification Scheme Manager

12 October 2016  
Date of Issue

04 September 2001  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



## Appendix to Certificate No: 517b PRYSMIAN CABLE & SYSTEMS LIMITED

Issue: 06

Product name				LPCB Ref. No.
FP400 Fire Resistant Cable				517b/01
Nominal csa of conductor (mm <sup>2</sup> )	Core Construction (excluding drain wire and earth)	BS 6387	EN 61034-2	EN 60754-1 (outer covering)
70	4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
95	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
120	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
150	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
185	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
240	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
300	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI
400	2, 3 & 4 <sup>(1)</sup>	CWZ	>60%	<0.5% HCI

**Uo/U 600/1000V**

**Notes:**

1. Stranded conductor only.
2. Testing of the FP400 range with diameters greater than 20mm were successfully carried out in accordance with Clause 17.6.2 and Annex I of BS 7846:2015.

**Cross-Listed products and alternative branding are detailed on page 3.**

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Damien Ward*

Signed for LPCB

Damien Ward  
Certification Scheme Manager

12 October 2016  
Date of Issue

04 September 2001  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



## Appendix to Certificate No: 517b PRYSMIAN CABLE & SYSTEMS LIMITED

Issue: 06

LPCB Ref No.	Model No.	Alternative Model No.	Labelled	Distributors Cert/Ref No.
517b/01	FP400 95mm <sup>2</sup> - 400mm <sup>2</sup> at 2, 3 & 4 cores 70mm <sup>2</sup> at 4 cores	FTP 95mm <sup>2</sup> - 400mm <sup>2</sup> at 2, 3 & 4 cores 70mm <sup>2</sup> at 4 cores	Draka UK Ltd	1134f/01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Damien Ward*

Signed for LPCB

Damien Ward  
Certification Scheme Manager

12 October 2016  
Date of Issue

04 September 2001  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



**bre**

消防處  
牌照及審批總區  
通風系統課

九龍尖沙咀東康莊道 1 號  
消防總部大廈 5 樓



FIRE SERVICES DEPARTMENT  
LICENSING & CERTIFICATION COMMAND

Ventilation Division

5/F, Fire Services Headquarters Building,  
No. 1 Hong Chong Road,  
Tsim Sha Tsui East, Kowloon,  
Hong Kong

本處檔號 Our Ref.: FP(LC) 317/21  
來函檔號 Your Ref.:  
圖文傳真 Fax: 2367 3206  
電話 Tel. No.: 2733 1557

24 March 2017

Prysmian Hong Kong Holding Limited  
Units 1511-12, 15/F., Lu Plaza  
2 Wing Yip Street, Kwun Tong  
Kowloon  
Hong Kong  
(Attn.: Mr. Stephen LAM)

Dear Sir,

**“Prysmian” FP400 Fire Resistant Cables**

I refer to your letter dated 16.12.2016 enclosing a set of catalogues and certificates and supplementary information submitted on 13.3.2017 with respect to the captioned fire resistant cables.


We have no objection in principle to the use of “Prysmian” FP400 fire resistant cables for fire service installations in Hong Kong subject to compliance with the Codes of Practice for Minimum Fire Service Installations and Equipment and Inspection, Testing and Maintenance of Installations and Equipment, 2012 Edition, relevant FSD Circular Letters and according to the following details:

Manufacturer : Prysmian Cable & Systems Limited, UK  
Model : FP400  
Construction : Plain annealed copper conductor, mineral ceramic tape, cross link insulation, LSOH bedding, steel wire armour, LSOH sheath  
Conductor Size : 1.5 to 400 mm<sup>2</sup> inclusive with 2, 3 and 4 core  
Test Certificates : Certificate No. 077b (Issue: 13) of 28.10.2016 and 517b (Issue: 06) of 12.10.2016 issued by Loss Prevention Certification Board (LPCB)

/2...

- Test Standard & Result : a) For cables with size of 1.5 to 10 mm<sup>2</sup> with 2 core and 1.5 to 6 mm<sup>2</sup> with 3 and 4 core (with overall diameter not exceeding 20 mm):  
BS 6387: 2013 (Category C, W, Z)  
b) For cables with size of 16 to 400 mm<sup>2</sup> with 2 core, 10 to 400 mm<sup>2</sup> with 3 and 4 core (with overall diameter exceeding 20 mm):  
BS 7846: 2015 (Category F2)
- Quality Assurance Scheme : The manufacturer operates a quality management system to ISO 9001: 2008 certified by LPCB under Certificate No. 077 (Issue: 15) of 25.11.2016.
- Remark : a) The cables shall remain LPCB listed and valid certificates shall be maintained;  
b) The cables shall bear appropriate markings of the manufacturer and certification body for identification purpose;  
c) Our previous letter of the same series dated 17.10.2016 for the same fire resistant cables is hereby superseded; and  
d) This assessment is subject to review by February 2022.

Yours faithfully,



(LAM Sui-hang)  
for Director of Fire Services

SHL/chl  
FileCode: prysmian fp400 20170324.doc

**BISHOPSTOKE FIRE TEST LABORATORY**

**REPORT OF FIRE RESISTANCE TEST**

ORDER No. 11602710b

TEST STANDARD BS EN 50200 : 2006

Category/Classification PH 120

CABLE DESCRIPTION 4 x 6 mm<sup>2</sup> FP400 Black to BS7846

Cable diameter 20 mm Clip size -

**TEST CONDITIONS**

Test Voltage 1000 V Nominal flame temperature 850 °C

Test duration 120 mins

Ambient temperature 16 °C

TEST OBSERVATIONS No fuse ruptured or lamp extinguished.

RESULT Pass

Tested by R Buck

Witnessed by \_\_\_\_\_

Signed *R Buck*

Signed \_\_\_\_\_

Test date 17/10/2012



**BISHOPSTOKE FIRE TEST LABORATORY**

**REPORT OF FIRE RESISTANCE TEST**

ORDER No. 11602710a

TEST STANDARD BS EN 50200 : 2006

Category/Classification PH 120

CABLE DESCRIPTION 2 x 1.5 mm<sup>2</sup> FP400 Black to BS7846

Cable diameter 13.5 mm      Clip size AP13

**TEST CONDITIONS**

Test Voltage 1000 V      Nominal flame temperature 850 °C

Test duration 120 mins

Ambient temperature 16 °C

TEST OBSERVATIONS No fuse ruptured or lamp extinguished.

RESULT Pass

Tested by R Buck

Witnessed by \_\_\_\_\_

Signed *R-Buck*

Signed \_\_\_\_\_

Test date 15/10/2012



## Certificate of Product Approval

Licensee:

### **Prysmian Cables & Systems Ltd**

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Standard:

BS 7846:2015

Description:

Armoured fire resistant power cables

Details:

Resistance to fire - Category F2.

Materials:

Insulation GP 8, Sheath LTS 1

Brand Name:

FP400

Origin Mark:

PRYSMIAN (B) FP400 or (B) PRYSMIAN FP400

### Permissible Approval Marks:

**BASEC**

BASEC name



BASEC roundel

Signed for and on behalf of  
BASEC Group Ltd

*Kieran O'Brien* Date: 06/07/2023

Date of original issue: 17/03/1997

Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK  
Registered in England No. 13950143, Tel: +44 (0)1908 267300  
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:  
**11/08/2026**



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size -sqmm
4	N/A	Class 2	2	1.5	70
5	N/A	Class 2	3	1.5	70
6	N/A	Class 2	4	1.5	70
7	N/A	Class 2	5	1.5	10
8	N/A	Class 2	7	1.5	4
8	N/A	Class 2	12	1.5	4
8	N/A	Class 2	19	1.5	4
8	N/A	Class 2	27	1.5	4
8	N/A	Class 2	37	1.5	4

Signed for and on behalf of  
BASEC Group Ltd

*Kieran O'Brien* Date: 06/07/2023

Date of original issue: 17/03/1997

Check BASEC website to verify validity.

Page 2 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK  
Registered in England No.13950143, Tel: +44 (0)1908 267300  
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:  
**11/08/2026**

## Certificate of Product Approval

Licensee:

**Prysmian Cables & Systems Ltd**

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:  
Oak Road

Wrexham Industrial Estate, Wrexham, LL13 9PH, Clwyd, United Kingdom

Standard:  
BS 7846:2015

Description:  
Armoured fire resistant power cables

Details:  
Resistance to fire - Category F2.

Materials:  
Insulation GP 8, Sheath LTS 1

Brand Name:  
FP400

Origin Mark:  
PRYSMIAN (W) FP400

### Permissible Approval Marks:

**BASEC**

BASEC name



BASEC roundel

Signed for and on behalf of  
BASEC Group Ltd

*Kieran O'Brien* Date: 20/07/2023

Date of original issue: 27/09/2001

Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK  
Registered in England No. 13950143, Tel: +44 (0)1908 267300  
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:  
**11/08/2026**



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
4	N/A	Class 2	2	50	400
5	N/A	Class 2	3	50	400
6	N/A	Class 2	4	50	400

Signed for and on behalf of  
BASEC Group Ltd

*Kieran O'Brien* Date: 20/07/2023

Date of original issue: 27/09/2001

Check BASEC website to verify validity.

Page 2 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK

Registered in England No.13950143, Tel: +44 (0)1908 267300

Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:  
**11/08/2026**



**BRE Global**Bucknalls Lane  
Watford, Herts  
WD25 9XXT +44 (0)333 321 8811  
E [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
W [www.bre.co.uk/global](http://www.bre.co.uk/global)**bre**Mr R Colwell  
Prysmian Group  
Chickenhall Lane  
Eastleigh  
Hampshire  
SO50 6YU1 October 2015  
Our Ref. JM011015

Dear Ray

**LPCB Approval – Prysmian Group – FP400 Range and FTP Cable Range**

This letter is to confirm that the Prysmian Group products listed below have been successfully tested in accordance with BS 6387:2013. Testing of the FP400 and FTP range with diameters greater than 20mm were successfully carried out in accordance with Clause 17.4.3 and Annex L of BS 7846:2009.

Model No.	LPCB No.	Labelled As
FP400	077b	Prysmian Cable & Systems Limited
FP400 Fire Resistant Cable	517b	Prysmian Cable & Systems Limited
FTP	1134e	DRAKA UK Limited
FTP	1134f	DRAKA UK Limited

Assuring you of our best intentions at all times.

Yours sincerely,

**Jenny Morris**  
**Certification Scheme Manager**  
For and on behalf of BRE Global Ltd.  
Telephone +44(0)1923 665262  
[morrisje@bre.co.uk](mailto:morrisje@bre.co.uk)

5<sup>th</sup> January 2021

**To Whom It May Concern**

Dear Customers,

**Qualification of Prysmian and Draka Fire Resistant Cables for “Listed Product” of FSD**

Refer to FSD Circular Letter No. 3/2020 of 15 July, 2020, this is to inform that “Prysmian” and “Draka” fire resistant cables with respect to attached Appendix II are “Listed Product” online for public access accredited with Product Certification Body (PCB), which are LPCB and BASEC under the UKAS hierarchy partnering with Multilateral Recognition Arrangement (MLA) of HKCAS.

Therefore, prior acceptance by FSD is not required since the qualification of our fire resistant cables underlying with attached Appendix A, are online for validation with the following websites.

- LPCB with <https://www.redbooklive.com/check/> by entering the certificate number e.g. 077n for Prysmian FP600S, 1134d for Draka FTP 120 and etc.
- BASEC with <https://www.basec.org.uk/> by clicking “Company Search” to enter “Prysmian Cables & Systems Ltd” or “Draka UK Ltd” to choose the corresponding product certificates e.g. 017/004/330 for Prysmian FP600S, 189/001/071 for Draka FTP 120 and etc.

To apply for FSI inspection, Registered Fire Service Installation Contractors (RFSICs) are required to submit Equipment List (Annex III) along with FSI/501a Form. For Fire Resisting Cables of ours that are supported with corresponding certificates of Appendix A, a specimen of Equipment List (Annex III) whereas the wirings are applicable for installation, is enclosed for submission reference.

Our product catalogue and corresponding LPCB & BASEC certificates are available on request or online for downloading and we are at your disposal for further understanding should there be any queries.

Yours sincerely,  
For and on behalf of Prysmian Group, Hong Kong office



Stephen Lam  
Business Director  
Hong Kong and Macau Area


Encl: Appendix II – Listed Product  
Appendix A - Qualification of Prysmian and Draka Fire Resistant Cables  
Annex III – Equipment List

Listed Product for Prysmian and Draka Fire Resistant Cables

**Appendix II**

**Checking the Validity of Product Certification (Listed Product)**

**‘Product Certification’** means the certification of a product which has been carried out in accordance with the conformity assessment as required by respective product certification scheme. In general, product certification includes product testing, conformity assessment with certification and surveillance inspection as stipulated in ISO/IEC 17067. For more information on the product certification scheme, please consult the manufacturer or Product Certification Body.



**Abbreviations**

- PCB - Product Certification Body
- MLA - Multilateral Recognition Arrangement
- CCC - China Compulsory Certification System
- HKAS - Hong Kong Accreditation Service
- HKCAS - Hong Kong Certification Accreditation Scheme



## Appendix A - Qualification of Prysmian and Draka Fire Resistant Cables

Standard	PRYSMIAN	LPCB	BASEC	DRAKA	LPCB	BASEC
BS 6387 CWZ IEC 60331-21 BS 8592 IEC 60331-3 EN 50200 PH120 BS 8434-2	<b>FP 100</b>	077c 077p	017/004/343	<b>FT Sifer 950i</b>	1134c 1134g	189/001/080
BS 6387 CWZ IEC 60331-21	<b>FP 300</b>	077b 077e 517a		<b>FT Sifer 950s</b>	1134h	
BS 6387 CWZ BS 7629-1 (Standard) BS 5839-1 (Standard) EN 50200 PH60+Annex E	<b>FP 200</b>	077f	017/004/324	<b>FT 30 Saffire</b>	1134j	189/001/068
BS 6387 CWZ BS 7846-F2	<b>FP 400</b>	077b 517b	017/004/340 017/006/082	<b>FTP</b>	1134e 1134f	189/001/078 189/003/023
BS 6387 CWZ BS 7629-1 (Enhanced) BS 5839-1 (Enhanced) BS 8434-2 (120 mins) EN 50200 PH120	<b>FP Plus</b>	077g	017/004/325	<b>FT 120</b>	1134b	189/001/067
BS 8491 (120 mins) BS 7846-F120 BS 7846-F2	<b>FP 600S</b>	077n 517c	017/004/330 017/006/083	<b>FTP 120</b>	1134d	189/001/071 189/003/024

**Annex III**

**Fire Service Installations – Equipment List**

(Revised in July 2020)

(To be appended to Form FSI/501a)

FP Ref. no. ....

Address of Premises:.....

Item	System/ Equipment	Manufacturer/ model no./ part no. (a)	FSD Approval/ Acceptance Reference (If available) (b)	Listing Certificates/Records/Printouts/Documents issued by Product Certification Bodies / Product Certification System (c)	
				Name of Product Certification Body/ Product Certification System	Listing Certificates/Records/ Printouts/ Documents Number
<b>I</b>	<b><u>Fire resisting Cable</u></b>				
11	Audio / visual advisory system				
12	Automatic actuating device				
13	Automatic fixed installation other than water	Prysmian FP 600S		LPCB	077n 517c
14	Deluge system				
15	Drencher system				
16	Fire hydrant / hose reel system			BASEC	017/004/330 017/006/083
17	Fixed foam system				
18	Pressurization of staircase				
19	Ring main system with fixed pumps(s)				
110	Smoke extraction system				
111	Street fire hydrant system				
112	Water mist system	Draka FTP 120		LPCB	1134d
113	Water spray system				
114	Fire Service water supply system			BASEC	189/001/071 189/003/024
115	Emergency generator				
116	Emergency lighting				
117	Exit sign				
118	Fire alarm system				
119	Fire detection system				
120	Fireman's lift				
121	<u>Sprinkler system</u>				

This is to confirm that either original copies of above mentioned documents or their photocopies which have been checked as true and correct, are appended to this Equipment List.

..... (RC / ) .....  
 Full Name of FSI Contractor      Signature      Registration Number      Company Chop      Date